



Taluka Health Officer
Panchayat Samitee Mulshi(Paud)
Dist-Pune
No:-OWNO./HEALTH/WATER/64 /2026
Date:23/02/2026

**ANNEXURE C
APPENDIX-VIII**

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

It is certified that an inspection team headed by DR.WAMAN PGENGAJE TALUKA HEALTH OFFICER from TALUKA HEALTH OFFICE PANCHAYAT SAMITEE MULSHI (PAUD) inspected the SANSKRITI SCHOOL,BHUKUM PUNE GATE NO.1164,VILLAGE LAVALE-TAL.MULSHI,DIST.PUNE. 411021 on 16 FEB. 2026 and found that the POTABLE. SANSKRITI SCHOOL has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above is valid for the period from 23 Feb.2026 to 22 Feb.2027

सार्वजनिक आरोग्य विभाग
महाराष्ट्र शासन

(DR.WAMAN PGENGAJE)
TALUKA HEALTH OFFICER
PANCHAYAT SAMITEE MULSHI(PAUD)
TAL.MULSHI; DIST. PUNE

To,
PRINCIPAL,
SANSKRITI SCHOOL,BHUKUM PUNE
GATE NO.1164,VILLAGE LAVALE
TAL.MULSHI,DIST.PUNE. 412115

IP
Daini Joshi
Principal
Sanskriti School, Pune



Manager
Sanskriti School, Lavale
Tal. Mulshi, Pune



INSTA POLLUTECH LABS

Testing Services

'IMRAT', Lane No. B/23, Raikarnagar, Opp Mor Bunglow, Dhayarigaon,
Pune - 411041, Maharashtra (India) Tel.: 020-24392871 Mob.: +91 9422009576

Format No.: IPL/Form/17

Water Sample Analysis Report

REPORT NO.		IPL / T / 09 / 50083		DATE OF ISSUE		12 / 09 / 2026	
Name and Address		SANSKRITI SCHOOL (BHUKUM CAMPUS) Gat No. 1164, Ahead of Manas Lake, Village – Lavale, Tal. – Mulshi, Pune – 412115				Order Reference: -	
Sample Description / Type		NEW FILTRATION UNIT WATER SAMPLE		Sample Collected by		Party	
Date of Sample Receipt		08 / 09 / 2026		Sample Quantity / Packing		1000 ml	
Date of Start of Analysis		09 / 09 / 2026		Date of Completion of Analysis		12 / 09 / 2026	
SR. NO.	PARAMETER	UNIT	RESULT	LIMITS AS PER IS 10500:2012 [Max]	METHODS OF ANALYSIS		
A	ORGANOLEPTIC & PHYSICAL PARAMETERS						
1	Colour	Hazen	<2	5	IS: 3025 (Part 4) – 1983		
2	Odour	--	Agreeable	Agreeable	APHA 22 nd Edition, Part 2150B, Page 2-16		
3	pH	--	7.40	6.5 to 8.5	APHA 22 nd Edition, Part 4500-H ⁺ B, Page 4-92		
4	Taste	--	Agreeable	Agreeable	APHA 22 nd Edition, Part 2160B, Page 2-20		
5	Turbidity	NTU	<1	1	APHA 22 nd Edition, Part 2130B, Page 2-13		
6	TDS	mg/lit	138.2	500	APHA 22 nd Edition, Part 2540C, Page 2-65		
7	Calcium [as Ca]	mg/lit	11.2	75	APHA 22 nd Edition, Part 3500-Ca B, Page 3-67		
8	Chlorides [as Cl]	mg/lit	22.5	250	APHA 22 nd Edition, Part 4500-Cl ⁻ B, Page 4-75		
9	Fluoride	mg/lit	<0.2	1.0	APHA 22 nd Edition, Part 4500-F ⁻ D, Page 4-87		
10	Residual Free Chlorine	mg/lit	0.21	0.2 [MIN]	APHA 22 nd Edition, Part 4500-Cl ⁻ B, Page 4-60		
11	Iron [as Fe]	mg/lit	<0.075	0.3	APHA 22 nd Edition, Part 3110, Page 3-14, 3500 Fe B 3-77		
12	Magnesium [as Mg]	mg/lit	4.9	30	APHA 22 nd Edition, Part 3500, Page 3-84		
13	Nitrate	mg/lit	<1	45	APHA 22 nd Edition, Part 4500-NO ₃ ⁻ B, Page 4-122		
14	Sulphates [as SO ₄]	mg/lit	<1	200	APHA 22 nd Edition, Part 4500 SO ₄ ²⁻ E, Page 4-190		
15	Total Alkalinity as CaCO ₃	mg/lit	36.0	200	APHA 22 nd Edition, Part 2320 B, Page 2-34		
16	Total Hardness as CaCO ₃	mg/lit	48.0	200	APHA 22 nd Edition, Part 2340 C, Page 2-44		
B	BACTERIOLOGICAL PARAMETERS						
17	E – Coli	/100ml	Absent	Absent	IS: 1622 – 1981		
18	Total Coliform Bacteria/MPN	MPN/100ml	Absent	Absent	IS: 1622 – 1981		

Remarks/Observations: - Test results comply as per IS:10500 (Drinking water) for above parameters. Water is Potable.

Danish Joshi
Principal

Sanskriti School, Pune



End of Test Report
Page 1

[Signature]
Authorized Signatory

Results related to sample (s) drawn from client only

This certificate shall not be reproduced except in full without the written permission of authorized signatory INSTA POLLUTECH LABS, PUNE

[Signature]
Manager

Sanskriti School, Lavale

Tal. Mulshi, Pune

Environment Laboratory Recognized By MoEF, GOVERNMENT OF INDIA, NEW DELHI

UNDER E.P. ACT 1986, VIDE GR NO. 2850 (E) SR. NO. 102

E-mail: sanjeevkatariya@instapollutechlabs.com, instapollutech@gmail.com

Visit us at : www.instapollutechlabs.com